



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 26/05/2025

Shift: C

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 29	OLR ACTED(4TIMES)	RESET	00:30:00	03:40:00	
2	OHP	CO 35	OLR ACTED	RESET	03:30:00	03:40:00	
3	CHP	CC 203	OLR acted	reset done	23:00:00	23:05:00	
4	CHP	CC 32 , SCR 5	LT not working due to overtension acted	overtension released , then ok. again cable fell down ,winding done	00:00:00 01:00:00 03:15:00	00:30:00 02:00:00 03:25:00	
5	CHP	CC 33 , SCR 4	BC ZSS probe problem	Probe replaced and bypass removed	01:10:00	01:40:00	
6	CHP	CC 125	OLR acted	reset done	03:20:00	03:25:00	
7	CHP	CC 32 , SCR 5	LT not working	Drive tripped. track broken , informed to operation	03:45:00	04:00:00	
8	CHP	CC 131	Motor tripped on overload	reset done	05:30:00	05:35:00	
9	WT	OP 6	Power tripped	made on	02:30:00	02:40:00	
10	WT	OC 1A	ZSS cage stucked due to jamming	released , then ok	03:00:00	03:20:00	