



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 29/12/2025

Incharge(s): Amit Roy

Shift: B

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|------------------|---|---|----------|----------|---------|
| 1 | OHP | TT-2 on CO-22 | Reported position indication not coming | Wire came out of TB.Connected properly | 15:00:00 | 15:15:00 | |
| 2 | OHP | Stacker on CO-7A | LT not taking place | Boom reclaiming height not reached.Boom placed properly and tested okay | 20:00:00 | 20:15:00 | |
| 3 | CHP | Cc-201 | Reported tripped | OLR acted.Reset done | 14:45:00 | 14:55:00 | |
| 4 | CHP | CC 203 | P/C acted | Released and tested okay | 14:45:00 | 14:55:00 | |
| 5 | CHP | CC-32 | Reported tripped | OLR acted.Reset done | 17:30:00 | 17:35:00 | |
| 6 | CHP | CC-33 SCR-3 | B/C not running | OLR acted.Reset done | 17:40:00 | 17:50:00 | |
| 7 | CHP | Cc-39 SCR-6 | B/C not running | PLC recycled and tested okay | 18:24:00 | 18:40:00 | |
| 8 | CHP | Cc 105 SCR-10 | Slew not working | Wrong complaint | 20:00:00 | 20:25:00 | |
| 9 | CHP | Cc-44 | Reported tripped | OLR acted.Reset done | 21:05:00 | 21:10:00 | |
| 10 | CHP | Cc-117 | Reported tripped | OLR acted.Reset done | 19:00:00 | 19:30:00 | |
| 11 | CHP | CC-51 MPD | Reported tripped | OLR acted.Reset done(7 times) | 15:28:00 | 18:20:00 | |
| 12 | WT | OP-2 | Reported not moving | D-3 tripped.Reset done | 17:05:00 | 17:15:00 | |