



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 14/05/2025

Area: CHP

Equipment	Job
CC 102, CC 103	HOIST MAINTENANCE DONE
CC-231 tower lights	lamps and chokes removing work done
SCR-3	LT motor-9 meggar value found to be zero. Motor disconnected from circuit
SCR-4	LT motors checking and PCRD unwinding and winding checking done
CC-105,SCR-10	ppm done
Lighting	CC-33 flap gate LDB 4 pole isolator replaced with 32A MCB
lighting	CC-113 wall side T/E area 4no's 30w led fixing done