



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 25/08/2025

Area: CHP

Equipment	Job
CC 37	110 V SENSOR REPLACED AND BRS TAKEN IN CIRCUIT
CC 54	PC SWITCHES CHECKING DONE 2 SWITCHES REMOVED
SCR 8 ON CC 112	LOW ACC PR 1 KEPT IN CIRCUIT
R1 ON CC 33 INTERLOCK CAGE	BELT PIECE CANOPY FIXED
MACHINE INTER CHANGING DONE	S 2 TO CC 35 SCR1 TO CC 36
CC 49	MOTOR REPLACED
CC 40, 43, 48, 49	PPM DONE