



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 01/05/2025

Area: CHP

Equipment	Job
CC 54 OLR acting	Found deck sheets jamming at middle and tail end
SCR 5	HT cable inspected