



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 09/08/2025

Incharge(s): Lal Singh

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-18 FG	FLAP GATE TRIPPED	MADE ON	09:30:00	09:40:00	
2	OHP	CO-26 WOB	SLEW DRIVE TRIPPED	RESET DONE	11:00:00	11:15:00	
3	OHP	BRC ON CO -31	BC STOPPING BECAUSE OF CHUTE SENSOR MALFUNCTION	CHUTE SENSOR BYPASSED	11:00:00	11:30:00	
4	OHP	CO-67	TRIPPED ON OLR	RESET DONE	06:10:00	06:15:00	
5	OHP	CO-10A	TRIPPED ON OLR	RESET DONE	06:15:00	06:30:00	
6	OHP	CO-87	TRIPPED ON OLR	RESET DONE	09:15:00 09:40:00	09:20:00 09:45:00	
7	CHP	cc-51	TRIPPED ON OL	RESET DONE	07:40:00 08:15:00	07:45:00 08:20:00	
8	CHP	CC-29 FG	FLAP GATE TRIPPED	RESET DONE	07:25:00	07:30:00	
9	CHP	CC-105 SCR-7	LT M2 AND M3 TRIPPED	RESET DONE ... PCRD DRUM ARRESTED DUE TO MECH PROBLEM	07:45:00	08:00:00	
10	CHP	CC-44	TRIPPED ON OLR	RESET DONE	12:40:00	12:55:00	
11	CHP	CC-39	TRIPPED ON OLR	RESET DONE	13:50:00	14:00:00	
12	CHP	CC-38 SCR-6	BC STOPPING	CHECKED FOUND OK ... TESTED	13:15:00	13:35:00	
13	WT	OT-4	D-2 TRIPPED ON PGF-4 FAULT	RESET DONE	11:25:00	11:30:00	
14	WT	EOT- ORE	MCCB TRIPPED	MADE ON AND TESTED	11:00:00	11:05:00	