



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 10/10/2025

Shift: C

Incharge(s): Lal Singh,K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-12	CD MPCB TRIPPED	RESET DONE	04:30:00	04:40:00	
2	OHP	CO-10A	TRIPPED ON OLR	RESET DONE	22:30:00	22:40:00	
3	OHP	CO-26	TRIPPED ON OLR	RESET DONE	00:45:00 01:50:00 04:50:00	00:55:00 02:00:00 05:00:00	
4	OHP	TBS ON CO-7A	LT NOT WORKING	PCRD OT ACTED ... RELEASED	03:30:00	03:45:00	
5	OHP	WBR ON CO-64	LT NOT WORKING	M2 TRIPPED RESET DONE AND OT PCRD RELEASED	04:00:00	04:15:00	
6	OHP	WBR ON CO-6A	LT NOT WORKING	PCRD TRIP ... DOWN CONTACTOR STUCK .. POWER CABLE REMOVED AND TESTED	04:20:00	05:00:00	DOWN CO NTACTOR TO BE CHANGED
7	OHP	DB-1	TRIPPED ON OLR	RESET DONE	03:50:00	04:10:00	
8	CHP	CC-32 R-1	SLEW NOT WORKING	POTENTIOMETER IN ZERO .. SPEED INCREASED THEN OK	22:25:00	22:50:00	
9	CHP	CC-219	TRIPPED ON OLR	RESET DONE	23:20:00	23:30:00	
10	CHP	CC-108	TRIPPED ON OLR	RESET DONE	01:00:00	01:20:00	
11	CHP	CC-112 SCR-8	BC NOT RUNNING	STARTED AFTER FAULT RESET IN CABIN	05:30:00	05:40:00	
12	CHP	CC-36 SCR-1	BW TRIPPED ON OLR	RESET DONE	05:40:00	05:50:00	
13	WT	OT-4	D2 TRIPPED ON PGF4 FAULT	RESET DONE	00:35:00	00:40:00	