



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 06/05/2025

Area: WT

Equipment	Job
OP 9	modification job, all control cables removed from panels and 24 V relays fixed in drive panels
	after rake maintenance done

OP 3 & 6