



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 03/01/2026

Area: WT

| Equipment | Job |
|----------------------|---|
| CP 3 | Power cable and collectors and all motor terminations removed for sending repair |
| OP 4 | Anti collision sensor installed ,3*1.5 cu cable laid 30 mtrs, ST2 timer replaced and tested |
| OP 2 | Anti collision sensor checked ST2 timer replaced and tested |
| OP 2 | D3 checked ,O/L setting increased and dash pot oil replaced |
| OP 1,2,3,4,5,6 and 8 | After rake maintenance done |
| MIS | LC 2A and 2B cleaning done |