



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 31/12/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 50	olr acted	reset	23:30:00	23:38:00	
2	OHP	BRC on co 32	b/w 1 olr acted	reset	03:00:00	03:10:00	
3	OHP	co 29	olr acted	reset	04:45:00	04:50:00	
4	OHP	co 26	olr acted	reset	04:00:00	04:10:00	2 times
5	OHP	brc on co 34	CT not working,drive tripped	reset	04:50:00	05:05:00	
6	CHP	CC 33 scr3	slew not working,slew limit acted	released	01:05:00	01:20:00	
7	CHP	CC 104 scr9	slew not working,slew limit acted	limit released	03:05:00	03:30:00	
8	CHP	CC 39 SCr6	all drive not healthy found found upper house to lower house near TUL cable crushed due to over slew	informed to operation change the machine	05:50:00	06:00:00	pending
9	CHP	CC 51	mpd tripped on overload 10 times	reset	22:30:00	06:00:00	
10	CHP	CC 117	olr acted 4 times	reset	00:30:00	05:00:00	
11	CHP	cc131	motor tripped in olr	reset	00:25:00	06:00:00	3 times
12	WT	OT 2	D2 tripped in pgf1 fault continuously	reset it,mechanical adjusted the brake,operation cleaned the roller than 3 wagon tippled without tripping	22:30:00	02:00:00	checked 4 times with empty wagon tippler moving smoothly