



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 21/09/2025

Incharge(s): K SANKARA RAO

Shift: A

| Sl No | Area | Equipment         | Problem  | Action  | From     | To       | Remarks        |
|-------|------|-------------------|--|---|----------|----------|----------------|
| 1     | OHP  | TT-4              | REPORTED LT NOT WORKING CHECKED AND FOUND MPCB TRIP                                  | MADE ON THAN OOK  | 07:00:00 | 07:15:00 | DUE TO JAMMING |
| 2     | OHP  | TBS ON CO-7A      | REPORTED BOTH B/C S NOT RUNNING CHECKED AND FOUND RB/C JAMMING LB/C CONTROL MCB TRIP | CONTROL MCB MADE ON THAN OK   | 07:15:00 | 07:35:00 |                |
| 3     | OHP  | CO-26             | OLR ACTED  | RESET DONE  | 08:15:00 | 08:25:00 |                |
| 4     | OHP  | BRC ON CO-28      | LT NOT TAKING PLACE PCRD O/T ACTED   | RELEASED  | 08:15:00 | 08:30:00 |                |
| 5     | OHP  | WOBR ON CO-6A     | LT NOT TAKING PLACE M-2 OLR ACTED  | RESET DONE  | 11:30:00 | 11:45:00 |                |
| 6     | OHP  | CO-9              | OLR ACTED(2TIMES) DUE TO MATERIAL JAMMING  | AFTER CLEAR THE MATERIAL IN LOCAL MODE THAN OLR RESET DONE              | 11:50:00 | 12:10:00 |                |
| 7     | OHP  | CBMS -4A ON CO-2A | REPORTED STOPPING ON ZS CHECKED AND FOUND ROD STUCK WITH BELT                        | ROD REMOVED THAN OK   | 12:10:00 | 12:20:00 |                |
| 8     | OHP  | CO-29             | OLR ACTED  | RESET DONE  | 13:15:00 | 13:25:00 |                |
| 9     | OHP  | CBMS -4A          | FREQUENTLY STOPPING  | BY PASSED OPERATION REQUIREMENT   | 13:30:00 | 13:40:00 |                |
| 10    | CHP  | CC--51            | OLR ACTED (3TIMES) DUE TO FEEDING CONVEYOR   | RESET DONE  | 07:40:00 | 07:45:00 |                |
| 11    | CHP  | CC-32             | OLR ACTED  | RESET DONE  | 10:50:00 | 11:10:00 |                |
| 12    | CHP  | CC-36 SCR-1       | LUFFING NOT WORKING CHECKED AND FOUND DOWN LIMIT ACTED                               | DOWN LIMIT BYPASSED AFTER PLACE THE POSITION THEN LIMIT KEPT IN CIRCUIT | 11:00:00 | 11:20:00 |                |