



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 11/02/2026

Incharge(s): Nagendra Midde

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	OLR ACTED	RESET	21:00:00	21:10:00	
2	CHP	CC 219 RED	C/S ACTED	INFORMED TO OPRN	15:30:00	15:40:00	
3	CHP	SCR 6 ON CC 39 LT	M2 TRIP	MADE IT ON	15:30:00 21:15:00	15:40:00 21:25:00	
4	CHP	SCR 6 ON CC 39 SLEW	30 DEGREE LIMIT ACTED	LIMIT RELEASED THEN OK	20:10:00	20:20:00	
5	CHP	SCR 1 ON CC 34	SLEW RIGHT LIMIT ACTED DUE TO JAMMING	INFORMED TO OPRN	21:30:00	21:40:00	
6	CHP	CC 51	FEEDING CONVEYOR OLR ACTED	RESET	19:00:00	21:45:00	4 TIMES
7	CHP	CC 54	OLR ACTED	RESET	17:45:00	21:30:00	5 TIMES