



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 03/05/2025

Incharge(s): Saurabh Kumar Yadav

Shift: B

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-----------|---|--------------------|----------|----------|---------|
| 1 | OHP | BRC 28 | B/w 2 not moving, olr acted | reset it done | 19:15:00 | 19:30:00 | |
| 2 | OHP | CO 25 | olr acted | reset it done | 16:00:00 | 16:10:00 | |
| 3 | OHP | Co 78 | not healthy,e stop | emergency released | 19:45:00 | 19:55:00 | |
| 4 | OHP | wobr 26 | no lighting complaint,lighting mcb is in off | made it on | 18:20:00 | 18:30:00 | |
| 5 | CHP | CC 36 | ZSS not healthy,sensor cable loose connection | cable tightened | 15:20:00 | 15:30:00 | |
| 6 | CHP | CC 54 | OLr acted | reset it done | 18:30:00 | 18:35:00 | |
| 7 | CHP | CC 117 | olr acted | reset it done | 20:50:00 | 21:00:00 | |
| 8 | WT | co 3 (c) | mpcb trip due to jamming | made it on | 20:00:00 | 20:10:00 | |