



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 09/11/2025

Shift: B

Incharge(s): Amit Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	VF 17	Reported Tripped	M1 motor lug got cut.Rejoint done and tested okay	18:10:00	18:50:00	
2	OHP	TBS on CO-19	LBC ZSS bypassed	Probe damaged.Replaced and kept in line	14:20:00 19:05:00	14:35:00 19:20:00	
3	OHP	BRC on CO-30	Reported B/C not running	OLR acted.Reset done	16:35:00	16:50:00	
4	OHP	WOBR on CO-26	Reported B/C not running	Mechanical problem	20:25:00	20:35:00	Informed to mechanical
5	OHP	CO-29	Reported tripped	OLR acted.Reset done	21:00:00	21:10:00	
6	CHP	CC54	Reported tripped	OLR acted.Reset done(2times)	14:10:00 14:45:00	14:15:00 14:50:00	
7	CHP	Cc105	D/E CS acted	Due to jamming	15:53:00	16:10:00	Informed to operation
8	CHP	CC 47	Reported BRS acting	wrong complaint	16:05:00	16:20:00	
9	CHP	Cc 34 scr-1	Reported Luffing and slewing not working	Wrong complaint	16:20:00	16:30:00	
10	CHP	Cc 34 SCR-1	Reported luffing not working	OLR acted.Reset done	17:20:00	17:34:00	
11	CHP	Cc105 SCR-10	LT not working	PCRD guide area jamming	19:20:00	19:46:00	Informed to operation
12	CHP	CC 125	Reported tripped	OLR acted.Reset done(2 times)	20:03:00 21:05:00	20:08:00 21:10:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 09/11/2025

Incharge(s): Amit Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	CHP	CC103	Reported fail to start	checked and found PLC o/P relay high loose.ZSS not coming.Bypassed and given clearance	16:26:00	17:03:00	ZSS cage changed and ZSS kept in line
14	CHP	CC 29	FLap gate not healthy	OLR acted.Reset done	14:20:00	14:25:00	
15	WT	CO-3	Reported tripped	OLR acted due to jamming.Reset done(2 times)	17:00:00 17:15:00	17:10:00 17:20:00	
16	IOSA	BRC	Reported signal missing	Yard Zss cage stuck up with stone.Stone removed and tested okay	16:05:00	16:15:00	