



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 11/11/2025

Incharge(s): Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	VF1A	motor 1 mpcb tripped	made on	01:15:00	01:20:00	
2	OHP	TT2	IT not taking place,	power recycle done	00:15:00	00:30:00	
3	OHP	CO 26	OLr acted	reset	23:15:00	23:25:00	4times
4	OHP	CO 21	ZSS acted ,caged stucked	cage replaced	22:20:00	22:40:00	
5	OHP	BRC on CO 30	BC olr acted	reset	03:20:00	03:40:00	
6	CHP	CC 38 SCR 6	LT not working,drive trips	drive reset	03:50:00	04:00:00	fault codef30003
7	CHP	CC 201 and 203	mpd tripped	reset	04:10:00	04:25:00	
8	CHP	CC 38 SCR 6	bc not running,mpd tripped	reset	05:10:00	05:20:00	
9	CHP	CC 202	fail to start,drive ol	reset	05:40:00	05:50:00	
10	WT	OP3	not moving,d1 OLR acted,5A1 contactor stucked	olr reset,contactor released	23:50:00	00:10:00	
11	WT	cp2	not moving,emergency acted	released	05:00:00	05:15:00	
12	WT	OT 4	initial not coming	sensor adjusted	03:00:00	03:15:00	