



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 14/08/2025

Incharge(s): Amit Roy, K SANKARA RAO

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 16	REPORTED RED OLR ACTED(2TIMES)	RESET DONE	14:45:00	15:10:00	DUE TO MATERIAL OVER LOAD.RAN IN LOCAL AND CLEARED MATERIAL
2	OHP	CO-11(C/D)	NOT MOVING. CHECKED AND FOUND MPCB TRIPPED	MPCB MADE ON	14:50:00	15:00:00	DUE TO TRACK JAMMING
3	OHP	CO-11(B/D)	REPORTED RED CHECKED AND FOUND OLR ACTED (2TIMES)	RESET DONE	18:20:00	18:30:00	
4	OHP	CO-11(B/D)	REPORTED RED. CHECKED AND FOUND OLR ACTED DUE TO MATERIAL JAMMING	AFTER CLEAR THE MATERIAL THAN OLR RESET DONE	19:10:00	19:30:00	
5	OHP	BRC ON CO-28	B/C NOT RUNNING CHECKED OLR ACTED (2TIMES)	RESET DONE	17:40:00 18:50:00	17:50:00 19:00:00	
6	OHP	CO-29	REPORTED RED CHECKED AND FOUND OLR ACTED (2TIMES)	RESET DONE	18:45:00 20:30:00	18:50:00 20:45:00	
7	OHP	VS-4A	DRIVE NOT HEALTHY CHECKED AND FOUND NO ELECTRICAL PROBLEM	WRONG COMPLAINT	17:30:00	17:45:00	
8	OHP	WOBR ON CO-26	SLEW NOT TAKING PLACE CHECKED AND FOUND DRIVE TRIPPED ON OVERLOAD	RESET DONE AND TESTED OKAY	20:30:00	20:45:00	
9	OHP	CO-26	Reported not healthy	OLR acted.Reset done	21:50:00	22:00:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 14/08/2025

Shift: B

Incharge(s): Amit Roy,K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
10	CHP	CC-29 F/G	NOT MOVING CHECKED AND FOUND OLR TRIP	RESET DONE	14:20:00	14:35:00	
11	CHP	CC-23	REPORTED RED. CHECKED AND FOUND MPCB TRIP	MPCB MADE ON	17:30:00 18:30:00	17:35:00 18:55:00	DUE TO MATERIAL JAMMING
12	CHP	CC-34 SCR-2	Reported LT not taking place	OT acted due to machine at tail end side.Tension released and tested okay	15:35:00	15:45:00	
13	CHP	CC-40 SCR-3	Reported luffing not taking place	Checked and found filter clog in hydraulic pump.Informed to hydraulic in charge and rectified	17:00:00	17:15:00	
14	CHP	CC-34 SCR-2	Reported LT and Slew not moving	LT OT acted and slewing wrong complaint.OT released and tested okay	18:15:00	18:25:00	
15	CHP	CC-203 F/G 28	Reported position indication not showing in CCR	Bypassed and given clearance	18:25:00	18:35:00	
16	CHP	CC-51	Reported not healthy	MPD acted on overload due to over material on bed.Reset done(6times)	15:05:00 15:55:00 16:22:00 20:30:00 20:50:00 21:15:00	15:15:00 16:00:00 16:28:00 20:35:00 20:55:00 21:20:00	Decksheet jamming found
17	CHP	CC-51	Reported ZSS acting	Checked and found Drive pulley slipping	15:15:00	15:30:00	Informed to mechanical
18	CHP	CC-51	Reported BSS acting	BSS acted due to Belt off centering	17:50:00	18:00:00	Informed to mechanical



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 14/08/2025

Shift: B

Incharge(s): Amit Roy, K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
19	WT	OP-7,8	Reported not moving	I/C tripped in LC.Made on and tested okay	18:30:00	18:40:00	
20	WT	OP-8	Reported not moving	Emergency stop acted.	18:40:00	18:50:00	Informed to operation