



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 09/07/2025

Incharge(s): V Balaji Naik, G Eswara Rao

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO3B	ZSS complaint found Belt not rotating but pulley rotating due to over load	Informed to operation	04:35:00	04:40:00	
2	OHP	CO3B	Over load acted 3 times	Reset done	04:40:00	04:45:00	
3	OHP	WOBR on CO6A	Oprator cabin no lights found MCB trip	Made on	23:00:00	23:15:00	
4	OHP	WOBR on CO25	LT not working found PCRD over tension acted	PCRD over tension released then ok	03:00:00	03:20:00	
5	CHP	CC114	BRS bypassed as per operational request	Again in ckt as per operational request	01:00:00	05:50:00	
6	CHP	CC53	motor trip due to over load	Reset done	03:20:00	03:25:00	
7	CHP	CC20	ZSS acted found cage reversed condition	ZSS cage fixed then ok	22:00:00	22:05:00	
8	CHP	CC103	BRS bypassed as per operational requirement	bypass removed as per operational requirement	02:30:00	02:35:00	
9	WT	OP6	Drive 6 over load acted	Reset done	03:10:00	03:20:00	