



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 26/07/2025

Area: OHP

Equipment	Job
cr-2a	motor is replaced and testing done, bearing end shield danged motor shifted to ers.
co-8a,db-1	io bits were arranged as per new io list