



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 19/10/2025

Shift: A

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 11(c)	mpcb tripped	made it on	11:05:00	11:10:00	
2	OHP	BRC on CO 32	b/c stopping,cjd acted,cjd position problem	cjd bypass,LT and CT checked all ok	10:45:00	11:10:00	
3	OHP	BRC on CO 32	Lt not working,Skew acted,m6 mpcb tripped	skew reset,mpcb made on	09:00:00	09:20:00	
4	CHP	cc 51	olr acted	reset	12:00:00	12:05:00	
5	CHP	CC 51	MPD trips stop feeding conveyor	reset	07:00:00	13:45:00	10 times
6	CHP	CC 54	olr acted	reset	07:00:00	13:00:00	9 times
7	CHP	SCR 4 cc31	slew not working,slew on f/b of stand by bypass in i/o rack	removed it	06:00:00	06:50:00	
8	CHP	CC 104 SCR9	all drive not working,acb is in off	acb made on	07:45:00	07:55:00	
9	CHP	SCR10 cc 105	slew not working,mpd trips	reset	08:05:00	08:15:00	
10	WT	OP 10	no communication,no power,acb tripped	made it on	08:05:00	08:15:00	
11	WT	OT 1	not moving,d1 tripped in pgf1 fault	reset	06:50:00	06:55:00	
12	WT	OT 5	clamp,unclamp not working,control fuse blown in i/o rack	fuse replaced	11:20:00	11:30:00	
13	IOSA	TBS	leftb boom complaint,selector in local	changed local to remote	06:25:00	06:50:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 19/10/2025

Incharge(s): Saurabh Kumar Yadav

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	IOSA	OLd wobr FLS	luffing not working,pump healthy all ok	not running even after manually	13:30:00	14:00:00	mechanical people are working along with electrical