



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 28/05/2025

Area: CHP

| Equipment | Job |
|--------------------------------|--|
| CM 19,CM 18 | Rooms cleaning done |
| SCR 2 | CD to IO rack control cable got damaged at cabin,rectified and tested slew drive |
| SCR 5 | PCRD OLR replaced |
| CC 202,131,53 | New lamp fixtures provided and lighting rectification done |
| CC 215,216,217,218,220,221,222 | PPM was done |
| CC 49 | BRS Receiver replaced and kept in ckt |
| CC 31.33,125,108 | Running inspection was done |