



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 21/11/2025

Incharge(s): Saurabh Kumar Yadav

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CC 105 SCR10	pcrd cable zigzag,guide problem	informed mechanical	07:10:00	07:20:00	
2	OHP	TBS on CO 7A	LT not taking place,reclaiming height not there	limit switch tied	09:40:00	09:55:00	
3	OHP	wobr on co 26	slew not working,ol acted	reset	11:35:00	11:50:00	
4	OHP	BRC on CO 32	b/w 2 not running,xmd card problem	xmd card replaced	11:40:00	11:59:00	
5	CHP	CC 28(B)	olr acted	reset	08:50:00	09:00:00	
6	CHP	CC 39 scr2	slew not working,joystick high missing	joystick high given	07:05:00	07:25:00	
7	CHP	CC 35 scr3	Lt not working,motor ol healthy bit missing,aux problem	replaced	10:35:00	10:50:00	
8	CHP	CC 51	mpd tripped 2 time	reset	12:20:00	12:25:00	
9	CHP	CC 54	olr acted	reset	08:30:00	12:25:00	4 times
10	IOSA	OC 7b	zss acted,due to stone stucked in cage	cage made free	06:45:00	07:00:00	