



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 22/12/2025

Shift: A

Incharge(s): G Eswara Rao

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 25	tripped on olr	reset done	06:15:00	06:25:00	
2	OHP	co 33m	zss acted due to jamming	inform to ope.to clear the jamming	07:00:00	07:10:00	
3	OHP	co 33s	zss acted due to jamming(motor is running)	inform to ope.	07:30:00	07:40:00	
4	CHP	scr 1on cc 34	wrong complaint	no elect. problem	06:25:00	06:35:00	
5	CHP	scr 7 on cc37	slew not working/spider brake fail fault	reset done	11:55:00	12:05:00	
6	CHP	scr 5 on cc32	luffing lower limit request from ope.	bypassed.	12:13:00	12:20:00	
7	CHP	cc 52	md tripped on olr	reset done	07:39:00	07:45:00	
8	CHP	cc52	tripped on olr	reset done	07:50:00	08:00:00	
9	CHP	cc58	tripped on olr	reset done	08:30:00	08:45:00	
10	CHP	cc51	mpd tripped on olr	reset done	09:10:00	09:20:00	
11	CHP	cc 114	tripped on olr	reset done	09:18:00	09:25:00	
12	CHP	cc54	tripped on olr	reset done	10:15:00	10:25:00	
13	CHP	cc131	tripped on olr	reset done	10:20:00 12:20:00	10:30:00 12:30:00	
14	CHP	lc 19	mcb tripped in plc panel/didnt found anyproblm	mcb made on.	10:33:00	10:45:00	
15	CHP	cc 52	tis chain got cut/bypassed .	for ope.request and again kept in ckt	07:30:00	10:30:00	