



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 22/10/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS ON CO-7A	L/LUFF UP NOT WORKING CHECKED AND FOUND DRIVE TRIP DUE TO BREAK PROBLEM	MECHANICAL BREAK ADJUSTED THAN DRIVE RESET AND BOOM KEPT IN RECLYMER HIGHT	09:00:00	09:45:00	
2	OHP	TBS ON CO-7A	REPORTED LT NOT TAKING PLACE	LEFT BOOM PLACED RECLYMER HIGHT AND LIMIT TIE WITH ROPE THAN LT OK	09:00:00	09:45:00	
3	OHP	CO-85	TRIPPED ON OLR	RESET DONE	13:30:00	13:40:00	
4	OHP	BRC ON CO-31	B/C TRIPPED ON OLR (2TIMES)	RESET DONE	13:40:00	14:00:00	
5	OHP	WOBR ON CO-26	SLEW NOT WORKING FOUND DRIVE TRIP	RESET DONE	13:45:00	13:55:00	
6	CHP	CC-112 SCR-8	LT NOT WORKING FOUND BREAK MPCB (Q23) TRIP	MADE ON THAN OK	06:30:00	06:40:00	
7	CHP	CC-112 SCR-8	B/C TRIPPED ON OLR	RESET DONE THAN OK	10:45:00	10:55:00	
8	WT	OT-5	NOT MOVE CHECKED AND FOUND DRIVE-1 TRIP (LOAD SLIPPING ) FAULT	RESET DONE	09:10:00 10:40:00	09:20:00 10:50:00	
9	IOSA	TBS ON OC-13A	LT NOT TAKING PLACE CHECKED AND FOUND LIMIT ACTED DUE TO JUNGLE	RELEASED THAN OK	13:40:00	13:50:00	