



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 29/01/2026

Area: WT

| Equipment        | Job  |
|------------------|--|
| CP 3 jobs        | I/C cable ,panel to Mast(95 *3 ) made ready              |
| CP 3 jobs        | power cable termination done @ panel side for drives     |
| CC 4 level       | Lighting complaint, rectified,3 nos L E D bulbs replaced |
| OP 1,4,5,6 and 8 | After rake maintenance done                              |