



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 16/12/2025

Area: WT

Equipment	Job
OP 1	Panel and Motor side ppm done, found D4 slip ring damaged,bypassed it
OP 3	Panel and Motor side ppm done,D3 lug @ O/L replaced
OP 7	Location of New modem( cambium make) changed @OT 4 cabin
OP 3 and 6	After rake maintenance done