



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 06/11/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 29	OLR acted	reset	22:45:00	22:55:00	
2	OHP	CO 26	olr acted	reset	04:10:00	04:15:00	
3	OHP	CO 5	olr acted 2 times due to material on conveyor	reset	04:00:00	04:35:00	
4	OHP	co 34	olr acted,jamming	reset	23:25:00	01:00:00	4 times
5	CHP	CC 125	olr acted	reset	23:55:00	00:05:00	
6	CHP	CC 37 SCR7	B/C OLR ACTED,due to jamming	reset	00:20:00	01:40:00	3 times
7	CHP	CC 104 SCR 9	slew and b/w not working,oil level low	checked electrical side all ok,informed mechanical	01:00:00	01:11:00	continue oil leakage not arrested by mechanical
8	CHP	CC 48	zss acted,cage flipped	cage adjusted	04:00:00	04:15:00	
9	CHP	CC 38 SCR6	LT not working found drive tripped	reset	04:50:00	05:50:00	
10	WT	OT 3	D1 tripped in encoder fault	reset	00:40:00 23:40:00	00:45:00 23:45:00	
11	WT	OT 1	d1 tripped in pgf1 fault	reset	01:10:00	01:15:00	