



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 09/01/2026

Shift: C

Incharge(s): Lal Singh,Lal Singh

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-----------------|---|--|----------------------------------|----------------------------------|---------|
| 1 | OHP | CO-28 BRC | PUMP NOT RUNNING ... ACC-2 ALARM | INFORMED MECH FOR NITROGEN FILLING NO ELECTRICAL PROBLEM | 03:30:00 | 03:45:00 | |
| 2 | OHP | CO-32 BRC | HYD PUMP NOT RUNNING ... OIL LEVEL LOW | INFORMED MECH | 23:00:00 | 23:15:00 | |
| 3 | OHP | CO-32 BRC | BW-1 NOT RUNNING STUCK | MADE FREE BY REV ROTATING | 01:15:00 | 01:30:00 | |
| 4 | OHP | CO-85 | TRIPPED ON OLR | RESET DONE | 00:05:00 23:02:00 | 00:20:00 23:09:00 | |
| 5 | CHP | cc-47 | FAIL TO START | POWER AND CONTROL RECYCLE THEN TESTED OK | 23:15:00 | 23:30:00 | |
| 6 | CHP | CC-104 SCR-9 | PLC COMMUNICATION FAILED EB03 FAULT | PLC POWER RECYCLED | 03:55:00 | 04:25:00 | |
| 7 | CHP | CC-18 | STOPPING ON ZSS | CAGE STUCK ... MADE FREE | 05:25:00 | 05:35:00 | |
| 8 | CHP | CC-114 | TRIPPED ON OLR | RESET DONE | 01:40:00 05:40:00 | 01:50:00 05:50:00 | |
| 9 | WT | OT-2 | TRIPPED ON PGF-1 FAULT | RESET DONE | 01:50:00 03:15:00 22:15:00 | 01:55:00 03:20:00 22:20:00 | |
| 10 | WT | OT-1 | WAGON OVER TRAVELED AND TIPPLER AT 20 DEGREE | SENSOR AND REV LIMIT BYPASSED TO BRING TIPPLER AT 0 DEGREE THEN KEPT IN CKT | 04:00:00 | 04:10:00 | |