



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 19/09/2025

Incharge(s): V Balaji Naik, Arnab Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	CHP	CC 26A	TT no power bcz of old joint insulation failure	MCCB tripped , insulation provided	15:15:00	15:30:00	
2	CHP	CC 44	motor MPD trips	reset	17:30:00	17:40:00	
3	CHP	cc 108	motor MPD trips	reset	18:55:00	19:00:00	
4	CHP	CC 39 SCR 3	b/c not running, LT motor 7 mpcb trips	reset	20:00:00	20:10:00	
5	WT	Ot1	drive 1 trips in pgf 1 fault	reset	16:05:00	16:10:00	