



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 08/08/2025

Incharge(s): V Balaji Naik, Saurabh Kumar Yadav

Shift: B

| Sl No | Area | Equipment   | Problem   | Action   | From     | To       | Remarks  |
|-------|------|-------------|---|--|----------|----------|----------|
| 1     | OHP  | CO7a        | reported no drives running found ACB tripped                          | ACB made on  | 17:40:00 | 18:00:00 |          |
| 2     | OHP  | CO32a       | BRS kept in ckt   | in ckt patch work done and mechanical dept requested | 21:10:00 | 21:10:00 |          |
| 3     | CHP  | CC 41       | cjd acted, bypass cable loose in i/o rack                             | cable tightened than healthy                         | 19:00:00 | 19:10:00 |          |
| 4     | CHP  | CC 38 SCR 6 | b/c not running, signal missing, for all conveyor                     | power recycle done in CCR micro plc                  | 19:10:00 | 19:35:00 |          |
| 5     | CHP  | CC 33 SCR4  | LT not working  | wrong complaint, informed operation                  | 19:50:00 | 20:00:00 |          |
| 6     | CHP  | CC51        | over load tripped 2 times due to over load (feeding conveyor stopped) | Reset done   | 18:10:00 | 18:20:00 |          |
| 7     | CHP  | CC114       | over load tripped   | Reset done   | 18:40:00 | 18:50:00 |          |
| 8     | WT   | CC3 Belt    | Over load Tripped   | Reset done   | 17:25:00 | 17:30:00 |          |
| 9     | WT   | SCO1A       | R phase lug damaged   | Replaced   | 17:30:00 | 17:30:00 | No delay |
| 10    | WT   | CT2 Inhaul  | olr tripped   | Reset done   | 18:30:00 | 18:40:00 |          |