



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 24/01/2026

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	vs 1a	tripped on olr	reset done	09:15:00	09:20:00	
2	OHP	CO-84	OLR ACTED	RESET DONE	08:50:00	09:00:00	
3	OHP	BRC ON CO-28	REPORTED LT NOT TAKING PLACE FOUND BREAK MPCB TRIP	MPCB MADE ON THAN OK	11:45:00	12:00:00	
4	CHP	cc 51	feeding conv. tripped on mpcb 2 times	made on	07:30:00 12:00:00	07:35:00 12:05:00	
5	CHP	cc 51	tripped on olr	reset done	07:24:00	07:28:00	
6	CHP	CC-216	OLR ACTED	RESET DONE	07:35:00	07:45:00	
7	WT	OP-2	COMMUNICATION PROBLEM	POWER RE-CYCLED THAN OK	08:45:00	08:50:00	
8	WT	CC-2 (C) DRIVE	OLR ACTED	RESET DONE	08:45:00	08:55:00	
9	WT	OP-5	DRIVE -5 TRIPPED ON OLR	RESET DONE	12:15:00	12:25:00	