



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 19/08/2025

Incharge(s): Lal Singh

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-26 WBR	SLEW DRIVE TRIPPED	RESET DONE	15:00:00	15:20:00	
2	OHP	WOBR ON 6A	LT NOT WORKING	M5 EARTH FAULT ... MOTOR REMOVED	14:30:00	15:00:00	
3	OHP	TBS ON CO -21	R -LUFF NOT WORKING	CONTROL RECYCLE THEN OK	19:30:00	20:00:00	
4	OHP	CO-29	TRIPPED ON OLR	RESET DONE	17:00:00	17:10:00	
5	OHP	BRC ON CO -31	BC TRIPPED ON OLR	RESET DONE	21:50:00	22:00:00	
6	CHP	cc-112 s-3	SLEW NOT WORKING	POTENTIOMETER IS AT ZERO ... INCREASED	14:05:00	14:15:00	
7	CHP	CC-126	FAIL TO START FAULT	NO POWER ... INC-2 TRIPPED ... MADE ON	16:20:00	16:40:00	
8	CHP	CC-111 SCR-8	AUX POWER AND ACB OFF	MADE ON	16:50:00	17:00:00	
9	CHP	CC-32 SCR-5	BC NOT RUNNING	YARD RUNNING SIGNAL NOT COMMING BECAUSE OFWRONG ROUTE SELECTION	17:08:00	17:28:00	
10	CHP	CC-36 SCR-6	SIGNAL MISSING	LT DONE THEN OK	17:30:00	18:00:00	
11	CHP	CC-40	TRIPPED ON OLR	RESET DONE	18:45:00	18:50:00	
12	CHP	CC-51	MPD TRIPPED 4 TIMES	RESET DONE (FEEDING CONVEYOR STOPPED)	18:20:00	21:30:00	
13	CHP	CC-132	TRIPPED ON OLR	RESET DONE	19:30:00	19:35:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 19/08/2025

Incharge(s): Lal Singh

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	CC-34 SCR-2	LT NOT WORKING	OVER TENSION ACTED	21:20:00	21:35:00	
15	CHP	CC-29	TRIPPED ON OLR	RESET DONE	18:25:00	18:30:00	
16	CHP	CC-28 FG	FLAP GATE TRIPPED	RESET DONE	20:10:00	20:20:00	
17	CHP	CC-19	TRIPPED ON OLR	RESET DONE	20:15:00	20:25:00	
18	WT	CO-3	BD TRIPPED ON OLR (4 TIMES)	RESET DONE	16:00:00	21:30:00	