



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 01/09/2025

Area: WT

Equipment	Job
MIS	Coupling fixed to 37 KW spare motor and End cover bolts found loose,tightening done
OT 1	In LDB, lug replaced to neutral cable and tightening done
OP 10	control circuit checked and lighting improved
OP 1	After rake maintenance done