



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 10/07/2025

Incharge(s): Saurabh Kumar Yadav

Shift: A

| Sl No | Area | Equipment    | Problem   | Action                            | From     | To       | Remarks |
|-------|------|--------------|---|-----------------------------------|----------|----------|---------|
| 1     | OHP  | CO 21        | stop in ZSS fault,zss cage module ok,belt slipping                      | informed operation and mech       | 08:45:00 | 08:55:00 |         |
| 2     | OHP  | BRC on 34    | LT not working,wrong complaint  | checked LT working ok             | 07:45:00 | 08:00:00 |         |
| 3     | OHP  | RSCO 9A      | olr acted   | reset                             | 10:30:00 | 10:40:00 |         |
| 4     | CHP  | CC 47        | motor fail to start   | power and control made off and on | 07:05:00 | 07:10:00 |         |
| 5     | CHP  | CC 45        | motor stop due to BS  | mechanical adjusted belt          | 07:25:00 | 07:35:00 |         |
| 6     | CHP  | CC 34 scr2   | LT not working,CAM switch common control supply missing , cable got cut | cable rejoined                    | 08:30:00 | 08:45:00 |         |
| 7     | CHP  | CC 104 SCR 9 | B/c not running,CJS acted,jamimng                                       | informed operation                | 09:30:00 | 09:40:00 |         |
| 8     | CHP  | CC 104 SCR 9 | B/C not running,  | fault reset done than ok          | 12:20:00 | 12:30:00 |         |
| 9     | CHP  | CC 34 SCR 2  | LT not taking place,OT acted  | OT released                       | 11:40:00 | 11:50:00 |         |
| 10    | WT   | CC 3(c)      | olr acted,mpcb tripped  | mpcb made on                      | 11:45:00 | 11:50:00 |         |
| 11    | IOSA | OLD WOBR     | LT not taking place,end limit acted due to bushes                       | released                          | 08:15:00 | 08:30:00 |         |