



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 11/08/2025

Area: WT

Equipment	Job
OT 1 and 2 Hoppers	Lighting improved, light fixers location re arranged ,3 nos 400 W fittings replaced
LC 9	Lighting , circuit problem rectified and one tube installed @ GE I/O panel
OP 2	After rake maintenance done