



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 31/10/2025

Shift: C

Incharge(s): Amit Roy,K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR ON CO-26	SLEW DRIVE TRIP	RESET DONE	00:10:00	00:20:00	
2	OHP	TBS ON CO-20	R/LUFF TRIPPED ON OLR	RESET DONE	01:30:00	01:45:00	
3	OHP	CO-26	TRIPPED ON OLR	RESET DONE	04:30:00	04:40:00	
4	OHP	BRC ON CO-32	REPORTED LT NOT TAKING PLACE FOUND MAIN CONTROL OFF CONDITION	MAIN CONTROL MADE ON THAN OK	02:30:00	02:40:00	
5	OHP	BRC ON CO-8A	REPORTED CT NOT WORKING FOUND F/LIMIT AND R/LIMIT FAULT INDICATION SHOWING	R/LIMIT WIRE LOOSE IN JB TIGHT THAN OK F/LIMIT CABLE JOINT DONE HIGH LOOP GIVEN IN CJB	02:30:00	03:20:00	
6	CHP	CC-52	MPD TRIPPED ON OLR (4TIMES)	RESET DONE	00:00:00	05:00:00	
7	CHP	CC-114	TRIPPED ON OLR(3TIMES)	RESET DONE	00:00:00	04:00:00	
8	CHP	CC-51	MPD TRIP (5TIMES) FEEDING CONVEYOR STOP	RESET DONE	00:00:00	03:30:00	
9	CHP	CC-31 SCR-4	LUFFING D/LIMIT ACTED	RELEASED	23:10:00	23:20:00	
10	CHP	CC-34 SCR-2	LT NOT TAKING PLACE NO PROBLEM	WRONG COMPLAINT	23:40:00	23:50:00	
11	CHP	CC-35	TRIPPED ON OLR (2TIMES)	RESET DONE	01:15:00 02:10:00	01:25:00 02:20:00	
12	CHP	CC-35 SCR-3	SLEW NOT WORKING FOUND R/LIMIT ACTED DUE TO SLEW MATERIAL JAMMING	INFORMED TO OPERATION	03:55:00	04:20:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 31/10/2025

Incharge(s): Amit Roy, K SANKARA RAO

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	WT	OC-1A	TRIPPED ON OLR DUE TO DRIVE PULLY JAMMING	RESET DONE	00:30:00	00:40:00	
14	WT	OP-10	NOT MOVE E/STOP ACTED COUPLING TIME	RELEASED	02:45:00	03:00:00	
15	WT	OP-10	DRIVE -6 TRIPPED OLR	RESET DONE	03:35:00	03:50:00	
16	WT	OP-10	NOT MOVE DRIVE -5 OLR ACTED DUE TO MOTOR TB FIXING BOLTS DAMAGED AND MOTOR TB FELL DOWN	TB REMOVED AND MOTOR DE-CLUTCH THAN RESET DONE	04:15:00	05:30:00	
17	WT	OP-7	NOT MOVE E/STOP ACTED COUPLING TIME	RELEASED	22:50:00	23:00:00	
18	IOSA	OLD WOBR ON 18A	B/W NOT RUNNING CHECKED AND FOUND XMD CHORD PROBLEM	CHORD REPLACED	22:30:00	04:00:00	