



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 02/07/2025

Area: IOSA

Equipment	Job
AIR COMPRESOR-2	VCU UNIT REMOVED FROM AIR COMPRESSOR-1 AND KEPT IN AIR COMPRESSOR-2 AND GIVEN CLEARANCE TO EnMD AFTER BREAKER CHECKING IN TEST POSITION.
OC-25A	PPM DONE ON MOTOR AND FIELD DEVICES.
OC-29A	FIELD DEVICES INSPECTION DONE.
INSPECTION	DONE ON OC-4A,5A,6A,7A,7B,7C,9A,11A,21A,23A,25A,29A CONVEYORS. DEFECTS RECORDED
LBDS-2	HOUSEKEEPING DONE IN LBDS2 BLDG