



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 29/11/2025

Area: WT

Equipment	Job
OP 4	Trolley line section Isolators maintenance done ,4 nos ( col no90,83,76 and 70)
CP 1 to 4	General inspection done,found one lug cut in CP3/D5 motor T B,replaced it
OP 2,5 and 7	General inspection done @parking zone
OP 1,4 and 6	After rake maintenance done