



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 14/11/2025

Area: WT

Equipment	Job
AF 2(O)	Drive control card and Key pad replaced , tested OK
CP 1	Panel and Motor side ppm done
OP 3	D6, motor TB fixing and stator cantactor kit and top unit fixing done
OP 2,3 and 4	After rake,maintenance done