



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 19/01/2026

Incharge(s): Nagendra Midde

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	tbs on co-22	LT NOT TAKING PLACE M-1 OLR ACTED	RESET DONE	10:40:00	11:00:00	
2	OHP	CO-84	OLR ACTED	RESET DONE	11:00:00	11:10:00	
3	OHP	WOBR ON CO-25	INTERLOCK ZSS PROBE DAMAGED	REPLACED WITH NEW PROBE THAN OK	08:45:00	09:00:00	
4	CHP	CC-39 SCR-6	REPORTED TUL C/S ACTED	PROBE CLEANED THAN OK	06:50:00	07:00:00	
5	CHP	CC-32	TRIPPED ON OLR	RESET DONE	08:45:00	08:55:00	
6	CHP	CC-31 TO CC-33	REPORTED YARD CONVEYORS NOT HEALTHY FOUND LC-17 (CM-22) ACB TRIP	ACB MADE ON THAN OK	09:50:00	10:10:00	
7	CHP	CC-37 SCR-7	LUFFING DOWN LIMIT ACTED	BYPASSED OPERATION REQUIREMENT	11:00:00	11:10:00	
8	CHP	CC-51	FEEDING CONVEYOR MPD TRIP (5TIMES)	RESET DONE	07:15:00	13:10:00	
9	CHP	CC-14	CONTROL MCB TRIP	MADE ON THAN OK	13:35:00	13:45:00	
10	WT	CO-2	REPORTED STOPPING ON ZSS CHECKED AND FOUND NO PROBLEM	CLEARANCE GIVEN THAN OK	10:10:00	10:20:00	