



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 08/08/2025

Area: OHP

Equipment	Job
CO1	2 LIGHTS GIVEN AND LDB MAINTAINENCE DONE
CO 6, 1A, 2A, 18, 3B	MOTOR VIBRATION , AND GREASING DONE
CC26, CC 26A, AND TTS	MOTOR AND PANEL PPM DONE
CO 7A and 8A	I/O MAINTAINENCE DONE
TBS 6	SHIFTED FROM CO 24 TO CO 7A
BRC4	CT LIMIT CHECKING DONE
CO 31	PC KEPT IN CIRCUIT
LC3	I/O RACK CABLE DRESSING DONE
LBDS6, LC2 , OM24	I/O RACK PPM DONE