



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 11/07/2025

Shift: B

Incharge(s): Arnab Roy

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|--------------------|--|---|----------------------|----------------------|---------------------|
| 1 | OHP | CO 13 | OLR acted | reset done | 17:55:00 | 18:05:00 | |
| 2 | OHP | CO 29 | OLR acted | reset done | 17:45:00 | 17:50:00 | |
| 3 | CHP | CC 203 | OLR acted | reset | 14:10:00 | 14:20:00 | |
| 4 | CHP | CC 201 | BC stopping frequently | Checked ZSS , working well | 15:25:00 | 15:50:00 | |
| 5 | CHP | CC 105 , SCR 10 | BC stopping frequently | ZSS cage stucked, made free | 17:00:00 | 17:20:00 | |
| 6 | CHP | CC 32, SCR 5 | LT not working | Overtension acted , released | 17:55:00 | 18:10:00 | |
| 7 | CHP | CC 32 , CC 33 | No power in machines | No power in IC , in LBDS feeder 25 tripped . Made on . Also 1 HT fuse blown in CC 33. Meggar done in CC 33, found okay and charged. Given clearance | 19:45:00 | 21:50:00 | |
| 8 | CHP | CC 131 | Tripped on overload (2 times) | reset done | 17:30:00 | 20:40:00 | |
| 9 | CHP | CC 113 A | Tripped on overload | reset done | 19:20:00 | 19:30:00 | |
| 10 | WT | OT 3 | D 1 tripped encoder fault | reset done | 14:50:00 | 15:00:00 | |
| 11 | WT | SCO 1A | Carriage drive tripped on overload | reset done | 17:40:00 | 17:45:00 | |
| 12 | WT | OT 4 | Not moving , D -2 tripped on pgf 1 fault. Again D-1 and D-2 tripped on pgf-1 fault | reset done | 18:00:00 20:50:00 | 18:05:00 21:00:00 | |
| 13 | WT | CO 4 | Pull chord acted | bypassed | 20:00:00 | 20:15:00 | informed to C shift |