



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 28/01/2026

Area: OHP

| Equipment | Job |
|----------------------|---|
| cr-1,2,3 | ht fuse healthy contact is taken to io rack as "panel healthy" bit and kept in circuit. |
| wobr-1 on repair bay | testing job, dressing and old cables removal is under progress. |
| CO-78,85,87 | MOTOR AND PANEL SIDE ppm is done |