



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 06/05/2025

Incharge(s): V Balaji Naik, G Eswara Rao

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO1A	BRs was bypassed on operational requiremwnt	Again put in ckt	23:00:00	04:30:00	
2	OHP	CO12	OLR acted	Reset done	00:45:00	00:55:00	
3	OHP	CO25	Over load acted 2 times	Reset done	03:15:00 04:10:00	03:25:00 04:30:00	
4	OHP	CO11 carriage	Carriage drive MPCB tripped	Reset done	05:40:00	05:50:00	
5	OHP	WOBR on CO25	Reported BW not working found oil level low	Informed to mexchanical to fill oil then ok	05:45:00	06:00:00	
6	CHP	CC131	Bunker position not shoing in CCR checked found TT not poitioned properly side	Phyxed in position then ok	23:00:00	23:20:00	
7	CHP	SCR4 on CC 33	LT not not working found PCRD over tension limit acted	PCRD over tension limit released then ok	23:20:00	23:30:00	
8	IOSA	CO7A	MPR tripped on Under voltage (UV1 fault )fault 2 times in B shift found that MPR is mall functioning	MPR bypassed by removing terminals B8 in MPR and tapped	22:00:00	22:35:00	May further follow to normalise
9	IOSA	OC2A	BRS by passed	As per operational request	22:50:00	23:00:00	