



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 06/01/2026

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-26	OLR ACTED (2TIMES)	RESET DONE	08:10:00 10:05:00	08:20:00 10:15:00	
2	OHP	WOBR ON CO-29	LT NOT TAKING PLACE FOUND DRIVE TRIP	RESET DONE	10:30:00	10:40:00	
3	OHP	WOBR ON CO-25	LUFF DOWN NOT WORKING CHECKED AND FOUND SWITCH PROBLEM	SWITCH TO BE REPLACED IN G-SHIFT	09:00:00	09:30:00	
4	OHP	TT-2 ON CO-15	LT NOT TAKING PLACE FOUND MPCB TRIPPED	MADE ON THAN OK	12:15:00	12:20:00	
5	CHP	CC-131	OLR ACTED (3TIMES)	RESET DONE	06:45:00	10:45:00	
6	CHP	CC-54	OLR ACTED (2TIMES)	RESET DONE	07:25:00 10:40:00	07:30:00 10:45:00	
7	CHP	CC-34 SCR-1	REPORTED LT NOT TAKING PLACE FOUND M-2 MPCB TRIP (2TIMES)	RESET DONE	06:20:00 09:40:00	06:30:00 09:50:00	
8	WT	OT-1	DRIVE -2 TRIP PGF-1 FAULT	RESET DONE	07:50:00	07:55:00	
9	WT	OT-2	DRIVE-1 PGF-1 FAULT TRIP	RESET DONE	06:35:00	06:40:00	