



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 31/12/2025

Shift: A

Incharge(s): K SANKARA RAO

| Sl No | Area | Equipment     | Problem  | Action                               | From                 | To                   | Remarks |
|-------|------|---------------|--|--------------------------------------|----------------------|----------------------|---------|
| 1     | OHP  | WOBR ON CO-25 | REPORTED SLEW NOT WORKING OLR ACTED  | RESET DONE THAN OK                   | 07:25:00             | 07:35:00             |         |
| 2     | OHP  | WOBR ON CO-29 | REPORTED ALL DRIVES ARE NOT WORKING FOUND LOWER LIMIT ACTED                      | RELEASED THAN OK                     | 09:10:00             | 09:25:00             |         |
| 3     | OHP  | WOBR ON CO-25 | REPORTED B/C NOT RUNNING CHECKED AND FOUND ZSS CAGE STUCK UP WITH STONE          | REMOVED THAN OK                      | 10:00:00             | 10:10:00             |         |
| 4     | OHP  | WOBR ON CO-29 | REPORTED LT NOT TAKING PLACE FOUND DRIVE AND M-3 TRIP (2TIMES) DUE TRACK JAMMING | RESET DONE AND INFORMED TO OPERATION | 10:10:00<br>10:35:00 | 10:25:00<br>10:45:00 |         |
| 5     | OHP  | TBS ON CO-7A  | REPORTED LT NOT TAKING PLACE FOUND INTERLOCK LUFF LIMIT PROBLEM                  | LIMIT PROPERLY TIE THAN OK           | 09:20:00             | 09:35:00             |         |
| 6     | CHP  | CC-13         | REPORTED NOT RUNNING CHECKED AND FOUND POWER MCCB OUT GOING JUMPERS MELTED       | REPLACED WITH CC-12 MADLU            | 09:45:00             | 10:15:00             |         |
| 7     | CHP  | CC-19         | REPORTED NOT HEALTHY OLR ACTED DUE TO MATERIAL JAMMING                           | RESET DONE AND INFORMED TO OPERATION | 09:33:00             | 09:40:00             |         |
| 8     | CHP  | CC-117        | OLR ACTED  | RESET DONE                           | 09:50:00             | 10:00:00             |         |
| 9     | CHP  | CC-51         | MPD TRIPPED (FEEDING CONVEYOR STOPPED) (20 TIMES)                                | RESET DONE                           | 09:20:00             | 13:10:00             |         |
| 10    | CHP  | CC-131        | TRIPPED ON OLR (4TIMES)  | RESET DONE                           | 09:00:00             | 12:20:00             |         |
| 11    | WT   | OT-2          | DRIVE -2 TRIP PGF-1 FAULT (2TIMES)   | RESET DONE                           | 12:30:00             | 12:35:00             |         |