



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 15/12/2025

Shift: A

Incharge(s): G Eswara Rao

| Sl No | Area | Equipment     | Problem  | Action                                    | From     | To       | Remarks         |
|-------|------|---------------|--|---|----------|----------|-----------------|
| 1     | OHP  | co 50         | tripped on olr   | reset done                                | 07:32:00 | 07:45:00 |                 |
| 2     | OHP  | co 29         | olr acted  | reset done                                | 13:00:00 | 13:10:00 |                 |
| 3     | OHP  | co 26         | tripped on olr   | reset done                                | 10:35:00 | 10:45:00 |                 |
| 4     | CHP  | cc 58         | tripped on olr due to over material.   | reset done 2 times.                       | 07:00:00 | 07:15:00 |                 |
| 5     | CHP  | cc 24         | C/ S .acted due to jamming   | reset done                                | 09:50:00 | 10:00:00 |                 |
| 6     | CHP  | cc 58 .TT     | TT LT NOT TAKING PLACE/pcrd cable R phase got short at old joint while doing LT due to material jamming and mpcb damaged | temporary joint done then given clearance | 10:45:00 | 11:40:00 | module replaced |
| 7     | CHP  | scr 6 on cc38 | tripped on olr.  | reset done                                | 06:30:00 | 06:45:00 |                 |
| 8     | CHP  | cc 35         | tripped on olr.  | reset done.                               | 08:11:00 | 08:20:00 |                 |
| 9     | CHP  | cc 125        | zss acting due more material on the conv.  | clear the material in local .then ok      | 09:30:00 | 09:55:00 |                 |
| 10    | CHP  | scr 4 on cc31 | pcrd cable looping on the ground/  | pcrd cable winding done .then ok          | 10:40:00 | 11:15:00 |                 |
| 11    | CHP  | cc 51         | mpd on olr due to feeding conver stopped   | reset done 5 times                        | 09:30:00 | 10:30:00 |                 |
| 12    | CHP  | cc 54         | tripped on olr   | reset done.                               | 12:00:00 | 12:05:00 |                 |
| 13    | CHP  | cc 117        | tripped on olr   | reset done                                | 11:20:00 | 11:25:00 |                 |
| 14    | CHP  | tis on cc130  | magnet mpcb tripped 5 time s due high current.   | reset done.                               | 08:15:00 | 12:30:00 |                 |
| 15    | CHP  | cc130 tis     | feed back kept bypass due to motor tipping   | at i/o rack                               | 12:35:00 | 12:40:00 |                 |