



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 29/04/2025

Shift: A

Incharge(s): V Balaji Naik,G Eswara Rao

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	brc on co 28	bw s are not running/ bw 1 mccb tripped	mccb made on	06:40:00	07:00:00	
2	OHP	brc on co 28	c t not taking place/chain got cut	inform to operation &mech.;	09:00:00	09:20:00	
3	OHP	co 35	tripped on olr	reset done	10:00:00	10:10:00	
4	OHP	brc on co31	bw s are not running/attended g shift for zss checking	zss kept in ckt.	10:45:00	11:00:00	
5	OHP	rsco 10a C/D	tripped on olr	reset done	11:00:00	11:20:00	
6	CHP	scr 5 on cc 32	bc not running/mccb tripped due to jamming (head end side)	mccb made on	11:50:00	12:00:00	
7	CHP	scr 5 on cc32	bc stopping inbetween/didnt found any elect.problem	inform to mech to check the fluid coupling oil	12:10:00	12:20:00	
8	CHP	CC 51A	TRIPPED ON OLR .	reset done	07:45:00	07:50:00	
9	CHP	SCR 4 on cc 33	no drives running/wrong complaint	fault reset done	06:35:00	06:45:00	
10	CHP	scr 6 on cc40	bc not running	power &control; off /on then ok	11:00:00	11:15:00	
11	CHP	SCR4 on CC33	LT NOT WORKING DUE TO FULL TRACK JAMMING	Informed to operation	13:30:00	13:40:00	
12	IOSA	wobr FLS	lt speed changed for machine placement	kept in normal speed 10HZ	09:10:00	09:45:00	