



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 26/09/2025

Area: WT

Equipment	Job
OP 1,3,5 and 8	after rake maintenance done
CP1 and CP 3	after rake maintenance done C P 3/D3 one lug replaced
EOT Crane(O)	panel and motor side ppm done,B phase termination found loose @pad,tightened .
EOT Crane(O)	Cabin walls welding done