



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 02/06/2025

Area: CHP

Equipment	Job
CC-25	Control cable checked and found cable burnt at slope area.10mtrs cable joint done,terminated and field devices checked and tested okay.ZSS module shifted at site.