



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 27/08/2025

Shift: C

Incharge(s): Amit Roy,K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-14	STOPPING ON ZSS CHECKED AND FOUND ZSS PROBE CABLE DAMAGED	ZSS PROBE CABLE RE-JOINT DONE THAN OK	01:45:00	02:00:00	
2	OHP	CO-29	OLR ACTED	OLR RESET DONE	03:20:00	03:30:00	
3	OHP	CC-113	STOPPING ON ZSS CHECKED AND FOUND	BELT MATERIAL OVER LOAD	23:40:00	23:55:00	IN FORM TO OPERA TION
4	OHP	CO-62(B/D)	REPORTED TRIPPED	OLR ACTED.RESET DONE	05:20:00	05:30:00	
5	OHP	TBS ON CO-7A	REPORTED NO POWER	ACB FOUND TO BE IN OFF CONDITION.MADE ON	22:20:00	22:40:00	
6	CHP	CC-51	OLR ACTED (2TIMES)	OLR RESET DONE	02:05:00 05:25:00	02:10:00 05:30:00	
7	CHP	CC-40 SCR-3	LT NOT TAKING PLACE	DRIVE TRIPPED. RESET DONE	23:40:00	23:50:00	
8	CHP	CC-44	REPORTED NOT HEALTHY	OLR TRIPPED.RESET DONE(3TIMES) DUE TO OVER MATERIAL ON BELT	00:05:00 00:40:00 01:10:00	00:10:00 00:45:00 01:15:00	INFORMED TO OPERA TION
9	CHP	CC-125	REPORTED TRIPPED	OLR ACTED.RESET DONE(2TIMES)	00:15:00 01:05:00	00:20:00 01:10:00	
10	CHP	CC40 SCR-3	REPORTED B/C DISCHARGE CHUTE SENSOR ACETD	CHECKED AND FOUND JAMMING	00:05:00	00:20:00	INFORMED TO OPERA TION
11	CHP	CC-38 SCR-6	REPORTED B/C NOT RUNNING	CHECKED AND FOUND TO BE RUNNING	03:30:00	03:45:00	WRONG C COMPLAINT



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 27/08/2025

Shift: C

Incharge(s): Amit Roy, K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
12	CHP	CC-33 R-1	REPORTED B/C NOT RUNNING	CHECKED AND FOUND INTERLOCK ZSS CAGE STUCK UP WITH COAL.MADE FREE AND TESTED OKAY	03:45:00	04:00:00	
13	IOSA	OC-7C	PENDING FROM B SHIFT.CONTACTOR TIPS MELTED.	CONTACTOR TIPS REPLACED WITH SPARE.MOTOR MEGGERED AND TESTED OKAY.CURRENTS FOUND BALANCED	22:00:00	23:10:00	